



# City of Oviedo Fire/Rescue

400 Alexandria Blvd, Oviedo Florida 32765  
Physical Location: 1934 West CR 419, Oviedo FL, 32766

---

## **GENERAL REQUIREMENTS** **FOR FOOD VENDORS**

### **Taste of Oviedo 2017**

Due to DBPR regulations and Florida Administrative Code 61C-4.016 all cooking and food preparations shall be done under cover, therefore the following requirements are outlined in the Florida Fire Prevention Code 5<sup>th</sup> Edition and shall be adhered to:

When cooking or warming under a tent/canopy like structure, the structure shall be an approved flame resistant material compliant with NFPA 701 standards. **The label shall be permanently affixed to the tent showing the fire resistant treatment or rating approval.** If utilizing a non-compliant tent/canopy like structure the operation shall be conducted outside of the structure and a minimum 10 feet away.

When cooking or warming occurs there shall be a minimum 10 foot clearance distance between your operation and adjacent event participants.

Cooking equipment in fixed, mobile, or temporary concessions, such as trucks, buses, trailers, in which cooking equipment produces grease laden vapors shall have a professionally certified NFPA 96 fire suppression system installed. This system must also be up to date with inspections (every 6 months)

When cooking or warming occurs by means of electricity, gas, charcoal/wood, the event participant shall have a minimum (1) one 2A-10BC fire extinguisher.

When cooking or warming involves a propane cylinder a minimum (1) one 2A-10BC fire extinguisher shall be provided.

When cooking involves equipment producing grease laden vapors a Class K fire extinguisher shall be provided in addition to the 2A-10BC fire extinguisher.

All fire extinguishers, to include new store bought types shall be serviced and tagged annually by a licensed State of Florida fire extinguisher contractor. To help assist with locating local licensed fire extinguishers contractors you may conduct an online search or yellow pages.

**Important- Fire extinguishers purchased from a hardware store do not come tagged by a licensed State of Florida fire extinguisher contractor; therefore you will need to contact a local licensed fire extinguisher contractor for this service.**

Deep fat fryers or pans with grease used for cooking shall have a metal cover plate, (lid) to put on them in case of fire or rain. There shall also be at least an 8-inch vertical or 16-inch horizontal separation from the deep-fat fryer and any adjacent open flame-cooking appliance.

All propane cylinders must be secured. Small cylinders (20lbs) can be place in a milk carton or any other carton type crate. Larger cylinders shall be secured to a stationary object, (fence, pole, etc.) except personal type grills with propane cylinders attached.

All propane cylinders (other than personal type grills with propane cylinders attached) shall be 10 feet from the cooking appliance with gas line(s) secured.

The filling of gas tanks on site is strictly prohibited.

There shall be no access to any of the cooking appliances by the general public.

**Fees for Services  
City of Oviedo Resolution 3064-15**

Explanation: The City of Oviedo has adopted a Fee Schedule for various services or loss of property applicable to all Special Events. The Fee Schedule for Fire-Rescue and associated services are described herein:

Loan	Fire Extinguisher Class ABC	\$50.00
Loan	Fire Extinguisher Class K	\$50.00
Loan	Fire Extinguisher Water	\$50.00

This service is intended to loan a vendor with a code compliant fire extinguisher when one is found to be in violation. It is not intended to serve as a rental service. The vendor is responsible for adhering to all fire extinguisher code requirements mentioned above. Fee is paid by vendor at event. Quantities are limited and based upon availability.

If property is not returned to the Fire Rescue Department at the conclusion of the event the following fee will be billed and event host will be notified to potentially exclude vendor in subsequent events:

Lost Property Cost Recovery	Fire Extinguisher Class ABC	\$100.00
Lost Property Cost Recovery	Fire Extinguisher Class K	\$150.00
Lost Property Cost Recovery	Fire Extinguisher Water	\$125.00



# City of Oviedo Fire/Rescue

400 Alexandria Blvd, Oviedo Florida 32765  
Physical Location: 1934 West CR 419, Oviedo FL, 32766

---

## GENERAL REQUIREMENTS FOR EVENT PARTICIPANTS

Taste of Oviedo March 11, 2017

*I have read and will comply with the requirements as listed above.  
Failure to do so will result in further action.*

_____ Company Name		_____ Contact Name	
_____			
_____ Address	_____ City	_____ State	_____ Zip
_____ Contact Number		_____ Contact Email	
_____			
_____ Signature		_____ Date	

**These requirements do not circumvent any other departmental requirements.  
Failure to adhere to the above requirements shall result in the immediate  
operation to cease.**

**Please complete this form in its entirety and return to the City of  
Oviedo Fire Prevention Division no later than (3) three business  
days prior to the scheduled event.**

**Completed forms shall be provided to the event host and emailed  
to [sginsburg@cityofoviedo.net](mailto:sginsburg@cityofoviedo.net) or [abaumann@cityofoviedo.net](mailto:abaumann@cityofoviedo.net) If  
faxing please send to 407-971-5810.**

